

# NEBRASKA STATE FIRE MARSHAL OFFICIAL INTERPRETATION



**Interpretation Number:** 96-05

**Date:** 01 February 2007 (original 27 Feb 1996)

**Pamphlet Number:** Title 156, NE. Accessibility Guidelines

**Section(s):** 4.22.3, 4.23.3

**Comments:**

Obstructions into the five foot turning radius and clear floor space for fixtures in toilet rooms

**Question:** Can the five foot turning radius and clear floor spaces for fixtures in toilet rooms be obstructed by a door swing into the toilet room?

**Response:** Yes, It is acceptable for the swing of a toilet room door to encroach into the turning space required in a toilet facility. Encroachment will be allowed if the following conditions are met:

1. The toilet room is for a single-occupant only.
2. Maneuvering clearance at the door, as required by Title 156, is fully observed.
3. A privacy lock is provided.

It is not allowable for door swing to encroach on any clear floor space required by fixtures.

**Signature:**

**Date:** 02/01/07

**Title:** John E. Falgione, State of Nebraska Fire Marshal